

# CERTIFICATE of Conformity



Certificate No.: MK 69247532 0001

Test Report No.: 28220810 003

Certificate Holder: **HAFLEX Maschinenbau GmbH, Blaubeurg Ventilatoren**  
51-53, Eurener Strasse  
D-54294 Trier  
Germany

Manufacturer: ---

Product: **FANS**  
**Duct fans**

Identification:	Type designation:	Rated power:
	Iso-Mix 100 y	24/26W
	Iso-Mix 125 y	25/30W
	Iso-Mix 150 y	45/52W
	Iso-Mix 160 y	45/52W
	Iso-Mix 200 y	78/110W
	Iso-Mix 250 y	127/178W
	Iso-Mix 315 y	213/313W

Where y = blank, T, US, USW1, FR, FR1, GI,  
GI1, G, G1, GT1, GTI1, GT, GT1

Trade Mark: **BLAUBERG**  
Rated Voltage: **220-240V, 50Hz**  
Protection class: **II**  
Degree of protection: **IPX4**

Tested according to: **EN 60335-2-80:2003+A1+A2**  
**EN 60335-1:2012**  
**EN 62233:2008**

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date of Issue:

Budapest, 2014.07.09

Certification Body



Veronika Schmidt